

# Generator Parallel Operation and MVar loading

Richard J Smith


*richardsmith@asia.com*

9 Jan 2015


# Introduction

- This presentation is designed to demonstrate the most efficient method of MVar sharing between multiple generators connected to a common busbar.
- It uses a mini grid with 2 generators and a system load (demand) of 56.5 MW +31.7 MVar.
- The 2 generating units are unevenly loaded at 39.5 and 17 MW respectively.


# Multiple Generators supplying Reactive Power in Parallel




Imagine a mini power grid which supplies a single transmission feeder to a factory or similar load.




# Multiple Generators supplying Reactive Power in Parallel



Assume we have a demand (Load) of 56.5 MW which also consumes 31.7 Mvar.



# Multiple Generators supplying Reactive Power in Parallel




First step is given the real power (56.5 MW) and reactive power (31.7 Mvar)  
find the Apparent power (MVA)


$$\text{Apparent power} = \sqrt{\text{true power}^2 + \text{reactive power}^2}$$

$$\text{Apparent power} = \sqrt{56.50^2 + 31.70^2}$$

$$\text{Apparent power} = 64.78 \text{ MVA}$$



# Multiple Generators supplying Reactive Power in Parallel




Second step take the Real Power (MW) and Apparent power (MVA) and find the Power Factor (p.f.)


$$\text{p.f.} = \frac{\text{Real power}}{\text{Apparent power}}$$

$$\text{p.f.} = \frac{56.50}{64.78}$$

$$\text{p.f.} = 0.872$$



# Multiple Generators supplying Reactive Power in Parallel




Third step is to use the above information and the system voltage (11000 V) to find the current flow (Amps) that must be supplied by the generators on line to meet demand.


$$\text{Current flow} = \frac{\text{Real power (W)}}{\text{voltage (V)} \times \text{p.f.}}$$

$$\text{Current flow} = \frac{56500000}{11000 \times 0.872}$$

$$\text{Current flow} = 5889.67 \text{ Amps}$$




# Multiple Generators supplying Reactive Power in Parallel




Therefore the real power demand (56.6 MW) and Reactive power demand (31.7 Mvar) can be met by generating 5889.67 Amps at 11000V.

Current flow = 5889.67 Amps







# Multiple Generators supplying Reactive Power in Parallel




To provide this load we have 2 generators (Unit 1 and Unit 2).




# Multiple Generators supplying Reactive Power in Parallel




Unit 1 is generating 39.5 MW with AVR on AUTO.




# Multiple Generators supplying Reactive Power in Parallel




Unit 2 is generating 17 MW with AVR on MANUAL.




## Multiple Generators supplying Reactive Power in Parallel




Between Unit 1 and Unit 2 - 31.7 Mvar must also be generated.




# Multiple Generators supplying Reactive Power in Parallel



NOTE: The machines are running at there most efficient when the combined current of both machines is least.




# Multiple Generators supplying Reactive Power in Parallel




Let's start by setting Unit 2 AVR Mvar setpoint to 0 Mvar (i.e. a power factor of 1). See results in table below.

	U1				U2			
Total	MW	MVARs	p.f.	Current	MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01




# Multiple Generators supplying Reactive Power in Parallel




NOTE: Setting Unit 2 to 0 Mvar causes Unit 1 operating point to be outside the limits of the capability diagram.

	U1				U2			
Total	MW	MVARs	p.f.	Current	MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01




# Multiple Generators supplying Reactive Power in Parallel




Let's increase Unit 2 AVR Mvar setpoint to +1 Mvar. Unit 1 will automatically respond by reducing its Mvar setpoint to ensure the same total is exported to meet demand.

Total MW	U1 MW	U1 MVARs	p.f.	Current	U2 MW	U2 MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69






# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	U1 MVARs	p.f.	Current	U2 MW	U2 MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70




# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	U1 MVARs	p.f.	Current	U2 MW	U2 MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96




# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33




# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65




# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69




# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23




# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00




# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74






# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18




# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04




# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04
56.50	39.55	19.70	0.90	4016.83	16.95	12.00	0.82	1888.06




# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04
56.50	39.55	19.70	0.90	4016.83	16.95	12.00	0.82	1888.06
56.50	39.55	18.70	0.90	3977.14	16.95	13.00	0.79	1942.01




# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04
56.50	39.55	19.70	0.90	4016.83	16.95	12.00	0.82	1888.06
56.50	39.55	18.70	0.90	3977.14	16.95	13.00	0.79	1942.01
56.50	39.55	17.70	0.91	3939.15	16.95	14.00	0.77	1998.63




# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04
56.50	39.55	19.70	0.90	4016.83	16.95	12.00	0.82	1888.06
56.50	39.55	18.70	0.90	3977.14	16.95	13.00	0.79	1942.01
56.50	39.55	17.70	0.91	3939.15	16.95	14.00	0.77	1998.63
56.50	39.55	16.70	0.92	3902.90	16.95	15.00	0.75	2057.72




# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04
56.50	39.55	19.70	0.90	4016.83	16.95	12.00	0.82	1888.06
56.50	39.55	18.70	0.90	3977.14	16.95	13.00	0.79	1942.01
56.50	39.55	17.70	0.91	3939.15	16.95	14.00	0.77	1998.63
56.50	39.55	16.70	0.92	3902.90	16.95	15.00	0.75	2057.72
56.50	39.55	15.70	0.93	3868.46	16.95	16.00	0.73	2119.06




# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04
56.50	39.55	19.70	0.90	4016.83	16.95	12.00	0.82	1888.06
56.50	39.55	18.70	0.90	3977.14	16.95	13.00	0.79	1942.01
56.50	39.55	17.70	0.91	3939.15	16.95	14.00	0.77	1998.63
56.50	39.55	16.70	0.92	3902.90	16.95	15.00	0.75	2057.72
56.50	39.55	15.70	0.93	3868.46	16.95	16.00	0.73	2119.06
56.50	39.55	14.70	0.94	3835.85	16.95	17.00	0.71	2182.46






# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04
56.50	39.55	19.70	0.90	4016.83	16.95	12.00	0.82	1888.06
56.50	39.55	18.70	0.90	3977.14	16.95	13.00	0.79	1942.01
56.50	39.55	17.70	0.91	3939.15	16.95	14.00	0.77	1998.63
56.50	39.55	16.70	0.92	3902.90	16.95	15.00	0.75	2057.72
56.50	39.55	15.70	0.93	3868.46	16.95	16.00	0.73	2119.06
56.50	39.55	14.70	0.94	3835.85	16.95	17.00	0.71	2182.46
56.50	39.55	13.70	0.94	3805.15	16.95	18.00	0.69	2247.75




# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04
56.50	39.55	19.70	0.90	4016.83	16.95	12.00	0.82	1888.06
56.50	39.55	18.70	0.90	3977.14	16.95	13.00	0.79	1942.01
56.50	39.55	17.70	0.91	3939.15	16.95	14.00	0.77	1998.63
56.50	39.55	16.70	0.92	3902.90	16.95	15.00	0.75	2057.72
56.50	39.55	15.70	0.93	3868.46	16.95	16.00	0.73	2119.06
56.50	39.55	14.70	0.94	3835.85	16.95	17.00	0.71	2182.46
56.50	39.55	13.70	0.94	3805.15	16.95	18.00	0.69	2247.75
56.50	39.55	12.70	0.95	3776.38	16.95	19.00	0.67	2314.77




# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04
56.50	39.55	19.70	0.90	4016.83	16.95	12.00	0.82	1888.06
56.50	39.55	18.70	0.90	3977.14	16.95	13.00	0.79	1942.01
56.50	39.55	17.70	0.91	3939.15	16.95	14.00	0.77	1998.63
56.50	39.55	16.70	0.92	3902.90	16.95	15.00	0.75	2057.72
56.50	39.55	15.70	0.93	3868.46	16.95	16.00	0.73	2119.06
56.50	39.55	14.70	0.94	3835.85	16.95	17.00	0.71	2182.46
56.50	39.55	13.70	0.94	3805.15	16.95	18.00	0.69	2247.75
56.50	39.55	12.70	0.95	3776.38	16.95	19.00	0.67	2314.77
56.50	39.55	11.70	0.96	3749.59	16.95	20.00	0.65	2383.38




# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04
56.50	39.55	19.70	0.90	4016.83	16.95	12.00	0.82	1888.06
56.50	39.55	18.70	0.90	3977.14	16.95	13.00	0.79	1942.01
56.50	39.55	17.70	0.91	3939.15	16.95	14.00	0.77	1998.63
56.50	39.55	16.70	0.92	3902.90	16.95	15.00	0.75	2057.72
56.50	39.55	15.70	0.93	3868.46	16.95	16.00	0.73	2119.06
56.50	39.55	14.70	0.94	3835.85	16.95	17.00	0.71	2182.46
56.50	39.55	13.70	0.94	3805.15	16.95	18.00	0.69	2247.75
56.50	39.55	12.70	0.95	3776.38	16.95	19.00	0.67	2314.77
56.50	39.55	11.70	0.96	3749.59	16.95	20.00	0.65	2383.38
56.50	39.55	10.70	0.97	3724.83	16.95	21.00	0.63	2453.43




# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	U1 MVARs	p.f.	Current	U2 MW	U2 MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04
56.50	39.55	19.70	0.90	4016.83	16.95	12.00	0.82	1888.06
56.50	39.55	18.70	0.90	3977.14	16.95	13.00	0.79	1942.01
56.50	39.55	17.70	0.91	3939.15	16.95	14.00	0.77	1998.63
56.50	39.55	16.70	0.92	3902.90	16.95	15.00	0.75	2057.72
56.50	39.55	15.70	0.93	3868.46	16.95	16.00	0.73	2119.06
56.50	39.55	14.70	0.94	3835.85	16.95	17.00	0.71	2182.46
56.50	39.55	13.70	0.94	3805.15	16.95	18.00	0.69	2247.75
56.50	39.55	12.70	0.95	3776.38	16.95	19.00	0.67	2314.77
56.50	39.55	11.70	0.96	3749.59	16.95	20.00	0.65	2383.38
56.50	39.55	10.70	0.97	3724.83	16.95	21.00	0.63	2453.43
56.50	39.55	9.70	0.97	3702.14	16.95	22.00	0.61	2524.82




56.50 MW  
31.70 MVAR

# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04
56.50	39.55	19.70	0.90	4016.83	16.95	12.00	0.82	1888.06
56.50	39.55	18.70	0.90	3977.14	16.95	13.00	0.79	1942.01
56.50	39.55	17.70	0.91	3939.15	16.95	14.00	0.77	1998.63
56.50	39.55	16.70	0.92	3902.90	16.95	15.00	0.75	2057.72
56.50	39.55	15.70	0.93	3868.46	16.95	16.00	0.73	2119.06
56.50	39.55	14.70	0.94	3835.85	16.95	17.00	0.71	2182.46
56.50	39.55	13.70	0.94	3805.15	16.95	18.00	0.69	2247.75
56.50	39.55	12.70	0.95	3776.38	16.95	19.00	0.67	2314.77
56.50	39.55	11.70	0.96	3749.59	16.95	20.00	0.65	2383.38
56.50	39.55	10.70	0.97	3724.83	16.95	21.00	0.63	2453.43
56.50	39.55	9.70	0.97	3702.14	16.95	22.00	0.61	2524.82
56.50	39.55	8.70	0.98	3681.56	16.95	23.00	0.59	2597.42




# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04
56.50	39.55	19.70	0.90	4016.83	16.95	12.00	0.82	1888.06
56.50	39.55	18.70	0.90	3977.14	16.95	13.00	0.79	1942.01
56.50	39.55	17.70	0.91	3939.15	16.95	14.00	0.77	1998.63
56.50	39.55	16.70	0.92	3902.90	16.95	15.00	0.75	2057.72
56.50	39.55	15.70	0.93	3868.46	16.95	16.00	0.73	2119.06
56.50	39.55	14.70	0.94	3835.85	16.95	17.00	0.71	2182.46
56.50	39.55	13.70	0.94	3805.15	16.95	18.00	0.69	2247.75
56.50	39.55	12.70	0.95	3776.38	16.95	19.00	0.67	2314.77
56.50	39.55	11.70	0.96	3749.59	16.95	20.00	0.65	2383.38
56.50	39.55	10.70	0.97	3724.83	16.95	21.00	0.63	2453.43
56.50	39.55	9.70	0.97	3702.14	16.95	22.00	0.61	2524.82
56.50	39.55	8.70	0.98	3681.56	16.95	23.00	0.59	2597.42
56.50	39.55	7.70	0.98	3663.11	16.95	24.00	0.58	2671.15




# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04
56.50	39.55	19.70	0.90	4016.83	16.95	12.00	0.82	1888.06
56.50	39.55	18.70	0.90	3977.14	16.95	13.00	0.79	1942.01
56.50	39.55	17.70	0.91	3939.15	16.95	14.00	0.77	1998.63
56.50	39.55	16.70	0.92	3902.90	16.95	15.00	0.75	2057.72
56.50	39.55	15.70	0.93	3868.46	16.95	16.00	0.73	2119.06
56.50	39.55	14.70	0.94	3835.85	16.95	17.00	0.71	2182.46
56.50	39.55	13.70	0.94	3805.15	16.95	18.00	0.69	2247.75
56.50	39.55	12.70	0.95	3776.38	16.95	19.00	0.67	2314.77
56.50	39.55	11.70	0.96	3749.59	16.95	20.00	0.65	2383.38
56.50	39.55	10.70	0.97	3724.83	16.95	21.00	0.63	2453.43
56.50	39.55	9.70	0.97	3702.14	16.95	22.00	0.61	2524.82
56.50	39.55	8.70	0.98	3681.56	16.95	23.00	0.59	2597.42
56.50	39.55	7.70	0.98	3663.11	16.95	24.00	0.58	2671.15
56.50	39.55	6.70	0.99	3646.84	16.95	25.00	0.56	2745.90






# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	U1 MVARs	p.f.	Current	U2 MW	U2 MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04
56.50	39.55	19.70	0.90	4016.83	16.95	12.00	0.82	1888.06
56.50	39.55	18.70	0.90	3977.14	16.95	13.00	0.79	1942.01
56.50	39.55	17.70	0.91	3939.15	16.95	14.00	0.77	1998.63
56.50	39.55	16.70	0.92	3902.90	16.95	15.00	0.75	2057.72
56.50	39.55	15.70	0.93	3868.46	16.95	16.00	0.73	2119.06
56.50	39.55	14.70	0.94	3835.85	16.95	17.00	0.71	2182.46
56.50	39.55	13.70	0.94	3805.15	16.95	18.00	0.69	2247.75
56.50	39.55	12.70	0.95	3776.38	16.95	19.00	0.67	2314.77
56.50	39.55	11.70	0.96	3749.59	16.95	20.00	0.65	2383.38
56.50	39.55	10.70	0.97	3724.83	16.95	21.00	0.63	2453.43
56.50	39.55	9.70	0.97	3702.14	16.95	22.00	0.61	2524.82
56.50	39.55	8.70	0.98	3681.56	16.95	23.00	0.59	2597.42
56.50	39.55	7.70	0.98	3663.11	16.95	24.00	0.58	2671.15
56.50	39.55	6.70	0.99	3646.84	16.95	25.00	0.56	2745.90
56.50	39.55	5.70	0.99	3632.78	16.95	26.00	0.55	2821.61




56.50 MW  
31.70 MVAR

# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	U1 MVARs	p.f.	Current	U2 MW	U2 MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04
56.50	39.55	19.70	0.90	4016.83	16.95	12.00	0.82	1888.06
56.50	39.55	18.70	0.90	3977.14	16.95	13.00	0.79	1942.01
56.50	39.55	17.70	0.91	3939.15	16.95	14.00	0.77	1998.63
56.50	39.55	16.70	0.92	3902.90	16.95	15.00	0.75	2057.72
56.50	39.55	15.70	0.93	3868.46	16.95	16.00	0.73	2119.06
56.50	39.55	14.70	0.94	3835.85	16.95	17.00	0.71	2182.46
56.50	39.55	13.70	0.94	3805.15	16.95	18.00	0.69	2247.75
56.50	39.55	12.70	0.95	3776.38	16.95	19.00	0.67	2314.77
56.50	39.55	11.70	0.96	3749.59	16.95	20.00	0.65	2383.38
56.50	39.55	10.70	0.97	3724.83	16.95	21.00	0.63	2453.43
56.50	39.55	9.70	0.97	3702.14	16.95	22.00	0.61	2524.82
56.50	39.55	8.70	0.98	3681.56	16.95	23.00	0.59	2597.42
56.50	39.55	7.70	0.98	3663.11	16.95	24.00	0.58	2671.15
56.50	39.55	6.70	0.99	3646.84	16.95	25.00	0.56	2746.90
56.50	39.55	5.70	0.99	3632.78	16.95	26.00	0.55	2824.61
56.50	39.55	4.70	0.99	3620.94	16.95	27.00	0.53	2898.19




56.50 MW  
31.70 MVAR

# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	U1 MVARs	p.f.	Current	U2 MW	U2 MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04
56.50	39.55	19.70	0.90	4016.83	16.95	12.00	0.82	1888.06
56.50	39.55	18.70	0.90	3977.14	16.95	13.00	0.79	1942.01
56.50	39.55	17.70	0.91	3939.15	16.95	14.00	0.77	1998.63
56.50	39.55	16.70	0.92	3902.90	16.95	15.00	0.75	2057.72
56.50	39.55	15.70	0.93	3868.46	16.95	16.00	0.73	2119.06
56.50	39.55	14.70	0.94	3835.85	16.95	17.00	0.71	2182.46
56.50	39.55	13.70	0.94	3805.15	16.95	18.00	0.69	2247.75
56.50	39.55	12.70	0.95	3776.38	16.95	19.00	0.67	2314.77
56.50	39.55	11.70	0.96	3749.59	16.95	20.00	0.65	2383.38
56.50	39.55	10.70	0.97	3724.83	16.95	21.00	0.63	2453.43
56.50	39.55	9.70	0.97	3702.14	16.95	22.00	0.61	2524.82
56.50	39.55	8.70	0.98	3681.56	16.95	23.00	0.59	2597.42
56.50	39.55	7.70	0.98	3663.11	16.95	24.00	0.58	2671.15
56.50	39.55	6.70	0.99	3646.84	16.95	25.00	0.56	2746.90
56.50	39.55	5.70	0.99	3632.78	16.95	26.00	0.55	2824.61
56.50	39.55	4.70	0.99	3620.94	16.95	27.00	0.53	2898.19
56.50	39.55	3.70	1.00	3611.35	16.95	28.00	0.52	2975.57




# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	U1 MVARs	p.f.	Current	U2 MW	U2 MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04
56.50	39.55	19.70	0.90	4016.83	16.95	12.00	0.82	1888.06
56.50	39.55	18.70	0.90	3977.14	16.95	13.00	0.79	1942.01
56.50	39.55	17.70	0.91	3939.15	16.95	14.00	0.77	1998.63
56.50	39.55	16.70	0.92	3902.90	16.95	15.00	0.75	2057.72
56.50	39.55	15.70	0.93	3868.46	16.95	16.00	0.73	2119.06
56.50	39.55	14.70	0.94	3835.85	16.95	17.00	0.71	2182.46
56.50	39.55	13.70	0.94	3805.15	16.95	18.00	0.69	2247.75
56.50	39.55	12.70	0.95	3776.38	16.95	19.00	0.67	2314.77
56.50	39.55	11.70	0.96	3749.59	16.95	20.00	0.65	2383.38
56.50	39.55	10.70	0.97	3724.83	16.95	21.00	0.63	2453.43
56.50	39.55	9.70	0.97	3702.14	16.95	22.00	0.61	2524.82
56.50	39.55	8.70	0.98	3681.56	16.95	23.00	0.59	2597.42
56.50	39.55	7.70	0.98	3663.11	16.95	24.00	0.58	2671.15
56.50	39.55	6.70	0.99	3646.84	16.95	25.00	0.56	2746.90
56.50	39.55	5.70	0.99	3632.78	16.95	26.00	0.55	2824.61
56.50	39.55	4.70	0.99	3620.94	16.95	27.00	0.53	2898.19
56.50	39.55	3.70	1.00	3611.35	16.95	28.00	0.52	2975.57
56.50	39.55	2.70	1.00	3604.03	16.95	29.00	0.50	3053.71




# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.

Total MW	U1 MW	U1 MVARs	p.f.	Current	U2 MW	U2 MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04
56.50	39.55	19.70	0.90	4016.83	16.95	12.00	0.82	1888.06
56.50	39.55	18.70	0.90	3977.14	16.95	13.00	0.79	1942.01
56.50	39.55	17.70	0.91	3939.15	16.95	14.00	0.77	1998.63
56.50	39.55	16.70	0.92	3902.90	16.95	15.00	0.75	2057.72
56.50	39.55	15.70	0.93	3868.46	16.95	16.00	0.73	2119.06
56.50	39.55	14.70	0.94	3835.85	16.95	17.00	0.71	2182.46
56.50	39.55	13.70	0.94	3805.15	16.95	18.00	0.69	2247.75
56.50	39.55	12.70	0.95	3776.38	16.95	19.00	0.67	2314.77
56.50	39.55	11.70	0.96	3749.59	16.95	20.00	0.65	2383.38
56.50	39.55	10.70	0.97	3724.83	16.95	21.00	0.63	2453.43
56.50	39.55	9.70	0.97	3702.14	16.95	22.00	0.61	2524.82
56.50	39.55	8.70	0.98	3681.56	16.95	23.00	0.59	2597.42
56.50	39.55	7.70	0.98	3663.11	16.95	24.00	0.58	2671.15
56.50	39.55	6.70	0.99	3646.84	16.95	25.00	0.56	2746.90
56.50	39.55	5.70	0.99	3632.78	16.95	26.00	0.55	2824.61
56.50	39.55	4.70	0.99	3620.94	16.95	27.00	0.53	2898.19
56.50	39.55	3.70	1.00	3611.35	16.95	28.00	0.52	2975.57
56.50	39.55	2.70	1.00	3604.03	16.95	29.00	0.50	3053.71
56.50	39.55	1.70	1.00	3598.99	16.95	30.00	0.49	3132.53




56.50 MW  
 31.70 MVAR

# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.




Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04
56.50	39.55	19.70	0.90	4016.83	16.95	12.00	0.82	1888.06
56.50	39.55	18.70	0.90	3977.14	16.95	13.00	0.79	1942.01
56.50	39.55	17.70	0.91	3939.15	16.95	14.00	0.77	1998.63
56.50	39.55	16.70	0.92	3902.90	16.95	15.00	0.75	2057.72
56.50	39.55	15.70	0.93	3868.46	16.95	16.00	0.73	2119.06
56.50	39.55	14.70	0.94	3835.85	16.95	17.00	0.71	2182.46
56.50	39.55	13.70	0.94	3805.15	16.95	18.00	0.69	2247.75
56.50	39.55	12.70	0.95	3776.38	16.95	19.00	0.67	2314.77
56.50	39.55	11.70	0.96	3749.59	16.95	20.00	0.65	2383.38
56.50	39.55	10.70	0.97	3724.83	16.95	21.00	0.63	2453.43
56.50	39.55	9.70	0.97	3702.14	16.95	22.00	0.61	2524.82
56.50	39.55	8.70	0.98	3681.56	16.95	23.00	0.59	2597.42
56.50	39.55	7.70	0.98	3663.11	16.95	24.00	0.58	2671.15
56.50	39.55	6.70	0.99	3646.84	16.95	25.00	0.56	2746.90
56.50	39.55	5.70	0.99	3632.78	16.95	26.00	0.55	2824.61
56.50	39.55	4.70	0.99	3620.94	16.95	27.00	0.53	2898.19
56.50	39.55	3.70	1.00	3611.35	16.95	28.00	0.52	2975.57
56.50	39.55	2.70	1.00	3604.03	16.95	29.00	0.50	3053.71
56.50	39.55	1.70	1.00	3598.99	16.95	30.00	0.49	3132.53
56.50	39.55	0.70	1.00	3596.24	16.95	31.00	0.48	3211.99

# Multiple Generators supplying Reactive Power in Parallel




Let's continue to increase Unit 2 AVR Mvar setpoint in steps of +1 Mvar and display the results on the table below.




Total MW	U1 MW	U1 MVARs	p.f.	Current	U2 MW	U2 MVARs	p.f.	Current
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04
56.50	39.55	19.70	0.90	4016.83	16.95	12.00	0.82	1888.06
56.50	39.55	18.70	0.90	3977.14	16.95	13.00	0.79	1942.01
56.50	39.55	17.70	0.91	3939.15	16.95	14.00	0.77	1998.63
56.50	39.55	16.70	0.92	3902.90	16.95	15.00	0.75	2057.72
56.50	39.55	15.70	0.93	3868.46	16.95	16.00	0.73	2119.06
56.50	39.55	14.70	0.94	3835.85	16.95	17.00	0.71	2182.46
56.50	39.55	13.70	0.94	3805.15	16.95	18.00	0.69	2247.75
56.50	39.55	12.70	0.95	3776.38	16.95	19.00	0.67	2314.77
56.50	39.55	11.70	0.96	3749.59	16.95	20.00	0.65	2383.38
56.50	39.55	10.70	0.97	3724.83	16.95	21.00	0.63	2453.43
56.50	39.55	9.70	0.97	3702.14	16.95	22.00	0.61	2524.82
56.50	39.55	8.70	0.98	3681.56	16.95	23.00	0.59	2597.42
56.50	39.55	7.70	0.98	3663.11	16.95	24.00	0.58	2671.15
56.50	39.55	6.70	0.99	3646.84	16.95	25.00	0.56	2746.90
56.50	39.55	5.70	0.99	3632.78	16.95	26.00	0.55	2824.61
56.50	39.55	4.70	0.99	3620.94	16.95	27.00	0.53	2898.19
56.50	39.55	3.70	1.00	3611.35	16.95	28.00	0.52	2975.57
56.50	39.55	2.70	1.00	3604.03	16.95	29.00	0.50	3053.71
56.50	39.55	1.70	1.00	3598.99	16.95	30.00	0.49	3132.53
56.50	39.55	0.70	1.00	3596.24	16.95	31.00	0.48	3211.99
56.50	39.55	0.00	1.00	3595.68	16.95	31.70	0.47	3267.96

# Multiple Generators supplying Reactive Power in Parallel




If we now add together the current flow in each generator we can see that the minimum combined current flow occurred when Unit 2 Mvar setpoint was at 9, 10 or 11 Mvar.

Total MW	U1 MW	U1 MVARs	p.f.	Current	U2 MW	U2 MVARs	p.f.	Current	Combined Current (Amps)
56.50	39.55	31.70	0.78	4607.78	16.95	0.00	1.00	1541.01	6148.78
56.50	39.55	30.70	0.79	4551.48	16.95	1.00	1.00	1543.69	6095.17
56.50	39.55	29.70	0.80	4496.32	16.95	2.00	0.99	1551.70	6048.01
56.50	39.55	28.70	0.81	4442.33	16.95	3.00	0.98	1564.96	6007.28
56.50	39.55	27.70	0.82	4389.56	16.95	4.00	0.97	1583.33	5972.89
56.50	39.55	26.70	0.83	4338.06	16.95	5.00	0.96	1606.65	5944.70
56.50	39.55	25.70	0.84	4287.86	16.95	6.00	0.94	1634.69	5922.55
56.50	39.55	24.70	0.85	4239.02	16.95	7.00	0.92	1667.23	5906.25
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00	5895.58
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74	5890.34
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18	5890.28
56.50	39.55	20.70	0.89	4058.17	16.95	11.00	0.84	1837.04	5895.21
56.50	39.55	19.70	0.90	4016.83	16.95	12.00	0.82	1888.06	5904.89
56.50	39.55	18.70	0.90	3977.14	16.95	13.00	0.79	1942.01	5919.15
56.50	39.55	17.70	0.91	3939.15	16.95	14.00	0.77	1998.63	5937.78
56.50	39.55	16.70	0.92	3902.90	16.95	15.00	0.75	2057.72	5960.62
56.50	39.55	15.70	0.93	3868.46	16.95	16.00	0.73	2119.06	5987.51
56.50	39.55	14.70	0.94	3835.85	16.95	17.00	0.71	2182.46	6018.32
56.50	39.55	13.70	0.94	3805.15	16.95	18.00	0.69	2247.75	6052.90
56.50	39.55	12.70	0.95	3776.38	16.95	19.00	0.67	2314.77	6091.15
56.50	39.55	11.70	0.96	3749.59	16.95	20.00	0.65	2383.38	6132.97
56.50	39.55	10.70	0.97	3724.83	16.95	21.00	0.63	2453.43	6178.27
56.50	39.55	9.70	0.97	3702.14	16.95	22.00	0.61	2524.82	6226.96
56.50	39.55	8.70	0.98	3681.56	16.95	23.00	0.59	2597.42	6278.98
56.50	39.55	7.70	0.98	3663.11	16.95	24.00	0.58	2671.15	6334.26
56.50	39.55	6.70	0.99	3646.84	16.95	25.00	0.56	2746.90	6392.75
56.50	39.55	5.70	0.99	3632.78	16.95	26.00	0.55	2824.61	6454.39
56.50	39.55	4.70	0.99	3620.94	16.95	27.00	0.53	2898.19	6519.12
56.50	39.55	3.70	1.00	3611.35	16.95	28.00	0.52	2975.57	6586.92
56.50	39.55	2.70	1.00	3604.03	16.95	29.00	0.50	3053.71	6657.73
56.50	39.55	1.70	1.00	3598.99	16.95	30.00	0.49	3132.53	6731.51
56.50	39.55	0.70	1.00	3596.24	16.95	31.00	0.48	3212.99	6808.23
56.50	39.55	0.00	1.00	3595.68	16.95	31.70	0.47	3267.96	6863.65








# Multiple Generators supplying Reactive Power in Parallel



This can be shown graphically as below;




# Multiple Generators supplying Reactive Power in Parallel




Lets concentrate on this area and redo the table just within these limits.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current	Combined Current (Amps)
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00	5895.58
56.50	39.55	23.60	0.86	4186.92	16.95	8.10	0.90	1707.90	5894.82
56.50	39.55	23.50	0.86	4182.27	16.95	8.20	0.90	1711.84	5894.11
56.50	39.55	23.40	0.86	4177.63	16.95	8.30	0.90	1715.82	5893.45
56.50	39.55	23.30	0.86	4173.01	16.95	8.40	0.90	1719.84	5892.85
56.50	39.55	23.20	0.86	4168.40	16.95	8.50	0.89	1723.89	5892.30
56.50	39.55	23.10	0.86	4163.81	16.95	8.60	0.89	1727.99	5891.80
56.50	39.55	23.00	0.86	4159.23	16.95	8.70	0.89	1732.12	5891.35
56.50	39.55	22.90	0.87	4154.67	16.95	8.80	0.89	1736.29	5890.96
56.50	39.55	22.80	0.87	4150.13	16.95	8.90	0.89	1740.50	5890.62
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74	5890.34
56.50	39.55	22.60	0.87	4141.08	16.95	9.10	0.88	1749.02	5890.10
56.50	39.55	22.50	0.87	4136.57	16.95	9.20	0.88	1753.34	5889.92
56.50	39.55	22.40	0.87	4132.09	16.95	9.30	0.88	1757.70	5889.78
56.50	39.55	22.30	0.87	4127.62	16.95	9.40	0.87	1762.09	5889.70
56.50	39.55	22.20	0.87	4123.16	16.95	9.50	0.87	1766.51	5889.67
56.50	39.55	22.10	0.87	4118.72	16.95	9.60	0.87	1770.98	5889.69
56.50	39.55	22.00	0.87	4114.29	16.95	9.70	0.87	1775.47	5889.77
56.50	39.55	21.90	0.87	4109.88	16.95	9.80	0.87	1780.01	5889.89
56.50	39.55	21.80	0.88	4105.49	16.95	9.90	0.86	1784.57	5890.06
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18	5890.28




# Multiple Generators supplying Reactive Power in Parallel




Again adding together the current flow in each generator we see that the minimum combined current flow occurs when Unit 2 AVR Mvar setpoint was +9.5 Mvar.

Total MW	U1 MW	U1 MVARs	p.f.	Current	U2 MW	U2 MVARs	p.f.	Current	Combined Current (Amps)
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00	5895.58
56.50	39.55	23.60	0.86	4186.92	16.95	8.10	0.90	1707.90	5894.82
56.50	39.55	23.50	0.86	4182.27	16.95	8.20	0.90	1711.84	5894.11
56.50	39.55	23.40	0.86	4177.63	16.95	8.30	0.90	1715.82	5893.45
56.50	39.55	23.30	0.86	4173.01	16.95	8.40	0.90	1719.84	5892.85
56.50	39.55	23.20	0.86	4168.40	16.95	8.50	0.89	1723.89	5892.30
56.50	39.55	23.10	0.86	4163.81	16.95	8.60	0.89	1727.99	5891.80
56.50	39.55	23.00	0.86	4159.23	16.95	8.70	0.89	1732.12	5891.35
56.50	39.55	22.90	0.87	4154.67	16.95	8.80	0.89	1736.29	5890.96
56.50	39.55	22.80	0.87	4150.13	16.95	8.90	0.89	1740.50	5890.62
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74	5890.34
56.50	39.55	22.60	0.87	4141.08	16.95	9.10	0.88	1749.02	5890.10
56.50	39.55	22.50	0.87	4136.57	16.95	9.20	0.88	1753.34	5889.92
56.50	39.55	22.40	0.87	4132.09	16.95	9.30	0.88	1757.70	5889.78
56.50	39.55	22.30	0.87	4127.62	16.95	9.40	0.87	1762.09	5889.70
56.50	39.55	22.20	0.87	4123.16	16.95	9.50	0.87	1766.51	5889.67
56.50	39.55	22.10	0.87	4118.72	16.95	9.60	0.87	1770.98	5889.69
56.50	39.55	22.00	0.87	4114.29	16.95	9.70	0.87	1775.47	5889.77
56.50	39.55	21.90	0.87	4109.88	16.95	9.80	0.87	1780.01	5889.89
56.50	39.55	21.80	0.88	4105.49	16.95	9.90	0.86	1784.57	5890.06
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18	5890.28




# Multiple Generators supplying Reactive Power in Parallel




Again adding together the current flow in each generator we see that the minimum combined current flow occurs when Unit 2 AVR Mvar setpoint was +9.5 Mvar.

Total MW	U1 MW	U1 MVARs	p.f.	Current	U2 MW	U2 MVARs	p.f.	Current	Combined Current (Amps)
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00	5895.58
56.50	39.55	23.60	0.86	4186.92	16.95	8.10	0.90	1707.90	5894.82
56.50	39.55	23.50	0.86	4182.27	16.95	8.20	0.90	1711.84	5894.11
56.50	39.55	23.40	0.86	4177.63	16.95	8.30	0.90	1715.82	5893.45
56.50	39.55	23.30	0.86	4173.01	16.95	8.40	0.90	1719.84	5892.85
56.50	39.55	23.20	0.86	4168.40	16.95	8.50	0.89	1723.89	5892.30
56.50	39.55	23.10	0.86	4163.81	16.95	8.60	0.89	1727.99	5891.80
56.50	39.55	23.00	0.86	4159.23	16.95	8.70	0.89	1732.12	5891.35
56.50	39.55	22.90	0.87	4154.67	16.95	8.80	0.89	1736.29	5890.96
56.50	39.55	22.80	0.87	4150.13	16.95	8.90	0.89	1740.50	5890.62
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74	5890.34
56.50	39.55	22.60	0.87	4141.08	16.95	9.10	0.88	1749.02	5890.10
56.50	39.55	22.50	0.87	4136.57	16.95	9.20	0.88	1753.34	5889.92
56.50	39.55	22.40	0.87	4132.09	16.95	9.30	0.88	1757.70	5889.78
56.50	39.55	22.30	0.87	4127.62	16.95	9.40	0.87	1762.09	5889.70
56.50	39.55	22.20	0.87	4123.16	16.95	9.50	0.87	1766.51	5889.67
56.50	39.55	22.10	0.87	4118.72	16.95	9.60	0.87	1770.98	5889.69
56.50	39.55	22.00	0.87	4114.29	16.95	9.70	0.87	1775.47	5889.77
56.50	39.55	21.90	0.87	4109.88	16.95	9.80	0.87	1780.01	5889.89
56.50	39.55	21.80	0.88	4105.49	16.95	9.90	0.86	1784.57	5890.06
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18	5890.28




# Multiple Generators supplying Reactive Power in Parallel



Also this combined current flow is the same value as we calculated was necessary to supply the demand if the power was generated at 11000 V.


Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current	Combined Current (Amps)
56.50	39.55	21.70	0.86	4191.58	16.95	8.00	0.90	1704.00	5895.58
56.50	39.55	23.60	0.86	4186.92	16.95	8.10	0.90	1707.90	5894.82
56.50	39.55	23.50	0.86	4182.27	16.95	8.20	0.90	1711.84	5894.11
56.50	39.55	23.40	0.86	4177.63	16.95	8.30	0.90	1715.82	5893.45
56.50	39.55	23.30	0.86	4173.01	16.95	8.40	0.90	1719.84	5892.85
56.50	39.55	23.20	0.86	4168.40	16.95	8.50	0.89	1723.89	5892.30
56.50	39.55	23.10	0.86	4163.81	16.95	8.60	0.89	1727.99	5891.80
56.50	39.55	23.00	0.86	4159.23	16.95	8.70	0.89	1732.12	5891.35
56.50	39.55	22.90	0.87	4154.67	16.95	8.80	0.89	1736.29	5890.96
56.50	39.55	22.80	0.87	4150.13	16.95	8.90	0.89	1740.50	5890.62
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74	5890.34
56.50	39.55	22.60	0.87	4141.08	16.95	9.10	0.88	1749.02	5890.10
56.50	39.55	22.50	0.87	4136.57	16.95	9.20	0.88	1753.34	5889.92
56.50	39.55	22.40	0.87	4132.09	16.95	9.30	0.88	1757.70	5889.78
56.50	39.55	22.30	0.87	4127.62	16.95	9.40	0.87	1762.09	5889.70
56.50	39.55	22.20	0.87	4123.16	16.95	9.50	0.87	1766.51	5889.67
56.50	39.55	22.10	0.87	4118.72	16.95	9.60	0.87	1770.98	5889.69
56.50	39.55	22.00	0.87	4114.29	16.95	9.70	0.87	1775.47	5889.77
56.50	39.55	21.90	0.87	4109.88	16.95	9.80	0.87	1780.01	5889.89
56.50	39.55	21.80	0.88	4105.49	16.95	9.90	0.86	1784.57	5890.06
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18	5890.28




Current flow = 5889.67 Amps

56.50 MW  
31.70 MVAR


# Multiple Generators supplying Reactive Power in Parallel




Unit 2 generating 17 MW and +9.5 Mvar. It is at a power factor of 0.87 lagging.




# Multiple Generators supplying Reactive Power in Parallel




Unit 1 is generating 39.5 MW and +22.2 Mvar and is also at a power factor of 0.87 lagging.



# Multiple Generators supplying Reactive Power in Parallel



So to minimise losses and operate differently sized or loaded machines feeding onto the same bus it is best to run them at the same power factor.





# The End