



Lets concentrate on this area and redo the table just within these limits.

Total MW	U1 MW	MVARs	p.f.	Current	U2 MW	MVARs	p.f.	Current	Combined Current (Amps)
56.50	39.55	23.70	0.86	4191.58	16.95	8.00	0.90	1704.00	5895.58
56.50	39.55	23.60	0.86	4186.92	16.95	8.10	0.90	1707.90	5894.82
56.50	39.55	23.50	0.86	4182.27	16.95	8.20	0.90	1711.84	5894.11
56.50	39.55	23.40	0.86	4177.63	16.95	8.30	0.90	1715.82	5893.45
56.50	39.55	23.30	0.86	4173.01	16.95	8.40	0.90	1719.84	5892.85
56.50	39.55	23.20	0.86	4168.40	16.95	8.50	0.89	1723.89	5892.30
56.50	39.55	23.10	0.86	4163.81	16.95	8.60	0.89	1727.99	5891.80
56.50	39.55	23.00	0.86	4159.23	16.95	8.70	0.89	1732.12	5891.35
56.50	39.55	22.90	0.87	4154.67	16.95	8.80	0.89	1736.29	5890.96
56.50	39.55	22.80	0.87	4150.13	16.95	8.90	0.89	1740.50	5890.62
56.50	39.55	22.70	0.87	4145.59	16.95	9.00	0.88	1744.74	5890.34
56.50	39.55	22.60	0.87	4141.08	16.95	9.10	0.88	1749.02	5890.10
56.50	39.55	22.50	0.87	4136.57	16.95	9.20	0.88	1753.34	5889.92
56.50	39.55	22.40	0.87	4132.09	16.95	9.30	0.88	1757.70	5889.78
56.50	39.55	22.30	0.87	4127.62	16.95	9.40	0.87	1762.09	5889.70
56.50	39.55	22.20	0.87	4123.16	16.95	9.50	0.87	1766.51	5889.67
56.50	39.55	22.10	0.87	4118.72	16.95	9.60	0.87	1770.98	5889.69
56.50	39.55	22.00	0.87	4114.29	16.95	9.70	0.87	1775.47	5889.77
56.50	39.55	21.90	0.87	4109.88	16.95	9.80	0.87	1780.01	5889.89
56.50	39.55	21.80	0.88	4105.49	16.95	9.90	0.86	1784.57	5890.06
56.50	39.55	21.70	0.88	4101.11	16.95	10.00	0.86	1789.18	5890.28

